MODELLING OF A PARABOLIC TROUGH COLLECTOR SYSTEM FOR HOT WATER PRODUCTION

S. Kalogirou*, S. Lloyd* and J. Ward*

Higher Technical Institute, P.O.Box 2423 Nicosia, Cyprus

⁺ University of Glamorgan, CF37 1DL, Pontypridd, U.K.

ABSTRACT

The modelling of a Parabolic Trough Collector System for hot water production is presented. This is followed by an experimental verification of the model and analysis of the experimental results. The difference between the predicted and actual results is about 7%. This variation is attributed to the difference of the actual weather during the tests compared to standard data taken from a "reference year" and the convection losses from the collector receiver which were not constant as accounted by the program.

INTRODUCTION

Cyprus began manufacturing solar water heaters in the early sixties. It is estimated that about 130,000 such heaters are in operation today which correspond to one heater for every 5 people on the island. These systems are almost exclusively of the flat-plate type. Opportunities still exist on the island for large scale hot water production for which the parabolic trough collector can be used more economically [1].

Cyprus enjoys an abundance of solar radiation which for a year with average weather conditions reaches 1725 kWh/m² (global), of which 69% (1188 kWh/m²) is direct and the rest 31% (537 kWh/m²) is diffuse radiation. All values apply for radiation falling to a horizontal surface.

Parabolic Trough Collectors (PTC) are generally employed for a variety of applications such as industrial steam production [2] and hot water production [1]. It has been shown that the use of PTC for hot water production can be more viable than the flat-plate type owing to its higher operating efficiency [1].

The scope of the modelling presented here is to investigate the performance of a PTC system and compare the results with the actual system performance.

THE REFERENCE YEAR

The operation of solar collectors and systems depends on the solar radiation input and the ambient air temperature. A typical year, called a Reference Year, is defined as a year which sums up all

the climatic information characterising a period equivalent to the mean life of the system. In this way the long term performance of a system can be calculated by simulating its performance over the reference year.

The reference year for the town of Nicosia, Cyprus was developed [3]. The actual reference year is a table of the hourly solar beam radiation and ambient air temperatures. The beam radiation is used here as PTCs with concentration ratios above 10, can only utilise this type of radiation [4].

SYSTEM MODELLING

The PTC system modelled here includes components as shown in Fig. 1 i.e. a PTC, a hot water storage tank, a circulating pump and a differential thermostat. The PTC system specifications are shown in Table 1.




FIGURE 1. The PTC system

Table 1. Parabolic trough collector system specification

ITEM	VALUE
Collector aperture area	1 m ²
Collector aperture	0.8 m
Aperture to length ratio	0.64
Rim angle	90°
Glass to receiver dia. ratio	2.17
Concentration ratio	21.2
Optimum water flow rate	0.012 kg/s
Differential thermostat setting	5°C
Storage capacity	90 1

A BASIC program was developed which used the data from the reference year and, the thermal and optical characteristics of the PTC system. These characteristics are determined from first principles, by the specifications given in Table 1. The hourly solar radiation values are modified

by the program to account for the collector inclination. For simplicity, it is assumed that no hot water is used. Also, the initial storage temperature is considered equal to the ambient temperature at the first hour of the day. The program calculations are performed for each minute throughout of the day, whilst the output from the program is given for every hour. The program flow chart is shown in Fig. 2.

Standard relations are used in the program for the calculation of the heat transfer coefficients. The useful power delivered by the collector is estimated by:

$$q_u = A_a F_R \left[n_o I - \frac{U_L(T_i - T_a)}{CR} \right]$$
 (1)

The thermal efficiency can be obtained by dividing q_u by I A_a . The optical efficiency is given by:

$$n_o = \rho \tau \alpha \gamma [(1 - A_f \tan(\theta)) \cos(\theta)]$$
 (2)

where A_f is the geometric factor determining the loss of area due to abnormal incidence effects and is given by:

$$A_{f} = \frac{\frac{2}{3} W_{a} h_{p} + f W_{a} \left(1 + \frac{W_{a}^{2}}{48 f^{2}}\right)}{A_{a}}$$
 (3)

For the evaluation of the intercept factor, γ , the method presented by Guven *et al.*[5] was used. The method requires the estimation of the random and nonrandom errors of the system which are then combined with the collector geometric parameters, concentration ratio and receiver diameter, to give the universal error parameters. These are then used for the estimation of γ .

For the heat loss coefficient, U_L, of the glazed tube receiver the formulation presented by Mullick et al. [6] was adopted.

A fully mixed storage tank is assumed. For submerged coils which is the case of the heat exchanger in the storage tank, the heat transfer coefficient, for the outside diameter of the heat exchanger pipe, can be obtained from [7]:

$$Nu_{p} = 0.53 \ (Gr \ Pr)^{0.25} \tag{4}$$

The overall heat transfer coefficient in this case based on the outside pipe diameter is given by [7]:

$$U = \left[\frac{D_o}{D_i} \frac{1}{h_f} + \frac{D_o \ln (D_o / D_i)}{2 k} + \frac{1}{h_o} \right]^{-1}$$
 (5)

The computed output from the program for the months April to June inclusive is shown in Table 2 whereas the mean daily energy collected for each month is shown in Table 3.

EXPERIMENTATION

A prototype model was constructed and tested over four months. Hence the accuracy with which

the simulation program predicts performance can be assessed. From the standard collector performance testing [8], some differences were observed between the theoretical values of the slope and intercept, and the experimental values. The results are shown in Table 4. A small difference is seen between the theoretical and experimental values with respect to the test intercept, whereas there is a large variation in test slope. Therefore the optical efficiency, no, which is deduced from the graph intercept is accurately predicted. The large variation of the test slope is due to a difference in the heat loss coefficient, U₁, which may be accounted for by the conduction/convection losses through the receiver support brackets. This difference is reduced from 24.9% to 5.7% when these losses are accounted for.

The results from the experiments carried out with the PTC system are presented in Table 5. The values shown are the mean values of the tests performed over a five day period during each month. As can be seen from this table the difference in the predicted and actual energy gain for all the months investigated is below 7% which may be considered reasonable.

Some of this difference may be accounted for by the following reasons:

1. The amount of cloud to sunshine hours. The amount of direct to diffuse radiation and the ambient air temperature may be different from those which are taken from reference year. This is strengthened by the fact that for the two Spring months of May and June, the difference is much smaller because the possibility of cloud is less.




FIGURE 2. Program flow chart

2.Convective losses. There was light wind in all test cases but its velocity varied. In the program a wind velocity of 1 m/s was considered as being constant.

Table 2. Simulation program output for months March to June

MONTH -M	NDCU.			
MONTH TIME	COL. OUT.	THERM.	USEFUL	STORAGE
TIME	TEMP.	EFFIC.	POWER	TEMP.
8.00	14.43	64.83	112.53	12.17
9.00	18.37	64.89	213.66	14.19
10.00	22.41	64.85	283.90	16.88
11.00	26.10	64.76	321.02	19.92
12.00	29.68	64.65	340.80	23.15
13.00	32.55	64.51	328.78	26.26
14.00	35.45	64.36	321.81	29.31
15.00	38.62	64.15	326.09	32.40
16.00	41.29	63.88	311.63	35.35
20.00				
MONTH =A	PRIL			
TIME	COL. OUT.	THERM.	USEFUL	STORAGE
	TEMP.	EFFIC.	POWER	TEMP.
8.00	21.58	61.45	164.75	18.36
9.00	25.79	61.44	256.55	20.79
10.00	29.72	61.37	311.77	23.74
11.00	33.71	61.28	346.96	27.03
12.00	36.44	61.14	329.52	30.15
13.00	39.38	60.97	323.36	33.21
14.00	42.15	60.80	313.36	36.18
15.00	44.57	60.52	293.93	38.96
16.00	45.89	60.08	241.11	41.25
MONTH -M	AY			
TIME	COL. OUT.	THERM.	USEFUL	STORAGE
TIME	COL. OUT. TEMP.	THERM. EFFIC.	POWER	TEMP.
TIME 8.00		EFFIC. 55.48	POWER 174.12	TEMP. 23.55
	TEMP.	EFFIC. 55.48 55.50	POWER 174.12 240.79	TEMP. 23.55 25.83
8.00	TEMP. 26.95 30.46 34.26	EFFIC. 55.48 55.50 55.44	POWER 174.12 240.79 292.92	TEMP. 23.55 25.83 28.61
8.00	TEMP. 26.95 30.46 34.26 37.48	EFFIC. 55.48 55.50 55.44 55.36	POWER 174.12 240.79 292.92 308.93	TEMP. 23.55 25.83 28.61 31.53
8.00 9.00 10.00 11.00 12.00	TEMP. 26.95 30.46 34.26 37.48 40.24	EFFIC. 55.48 55.50 55.44 55.36 55.27	POWER 174.12 240.79 292.92 308.93 303.63	TEMP. 23.55 25.83 28.61 31.53 34.41
8.00 9.00 10.00 11.00 12.00 13.00	TEMP. 26.95 30.46 34.26 37.48 40.24 42.16	EFFIC. 55.48 55.50 55.44 55.36 55.27 55.10	POWER 174.12 240.79 292.92 308.93 303.63 271.37	TEMP. 23.55 25.83 28.61 31.53 34.41 36.98
8.00 9.00 10.00 11.00 12.00 13.00	TEMP. 26.95 30.46 34.26 37.48 40.24 42.16 44.28	EFFIC. 55.48 55.50 55.44 55.36 55.27 55.10 54.93	POWER 174.12 240.79 292.92 308.93 303.63 271.37 255.71	TEMP. 23.55 25.83 28.61 31.53 34.41 36.98 39.40
8.00 9.00 10.00 11.00 12.00 13.00 14.00 15.00	TEMP. 26.95 30.46 34.26 37.48 40.24 42.16 44.28 46.33	EFFIC. 55.48 55.50 55.44 55.36 55.27 55.10 54.93 54.66	POWER 174.12 240.79 292.92 308.93 303.63 271.37 255.71 242.70	TEMP. 23.55 25.83 28.61 31.53 34.41 36.98 39.40 41.70
8.00 9.00 10.00 11.00 12.00 13.00	TEMP. 26.95 30.46 34.26 37.48 40.24 42.16 44.28	EFFIC. 55.48 55.50 55.44 55.36 55.27 55.10 54.93	POWER 174.12 240.79 292.92 308.93 303.63 271.37 255.71	TEMP. 23.55 25.83 28.61 31.53 34.41 36.98 39.40
8.00 9.00 10.00 11.00 12.00 13.00 14.00 15.00	TEMP. 26.95 30.46 34.26 37.48 40.24 42.16 44.28 46.33 47.80	EFFIC. 55.48 55.50 55.44 55.36 55.27 55.10 54.93 54.66	POWER 174.12 240.79 292.92 308.93 303.63 271.37 255.71 242.70	TEMP. 23.55 25.83 28.61 31.53 34.41 36.98 39.40 41.70
8.00 9.00 10.00 11.00 12.00 14.00 15.00 16.00	TEMP. 26.95 30.46 34.26 37.48 40.24 42.16 44.28 46.33 47.80	EFFIC. 55.48 55.50 55.44 55.36 55.27 55.10 54.93 54.66 54.33	POWER 174.12 240.79 292.92 308.93 303.63 271.37 255.71 242.70	TEMP. 23.55 25.83 28.61 31.53 34.41 36.98 39.40 41.70
8.00 9.00 10.00 11.00 12.00 13.00 14.00 15.00	TEMP. 26.95 30.46 34.26 37.48 40.24 42.16 44.28 46.33 47.80	EFFIC. 55.48 55.50 55.44 55.36 55.27 55.10 54.93 54.66	POWER 174.12 240.79 292.92 308.93 303.63 271.37 255.71 242.70 212.06	TEMP. 23.55 25.83 28.61 31.53 34.41 36.98 39.40 41.70 43.70
8.00 9.00 10.00 11.00 12.00 13.00 14.00 15.00 MONTH =J	TEMP. 26.95 30.46 34.26 37.48 40.24 42.16 44.28 46.33 47.80 UNE COL. OUT. TEMP.	EFFIC. 55.48 55.54 55.36 55.27 55.10 54.93 54.66 54.33 THERM. EFFIC.	POWER 174.12 240.79 292.92 308.93 303.63 271.37 255.71 242.70 212.06	TEMP 23.55 25.83 28.61 31.53 34.41 36.98 39.40 41.70 43.70
8.00 9.00 10.00 11.00 13.00 14.00 15.00 16.00 MONTH =J	TEMP. 26.95 30.46 34.26 37.48 40.24 42.16 44.28 46.33 47.80 UNE COL. OUT. TEMP. 32.76	EFFIC. 55.48 55.50 55.44 55.36 55.27 55.10 54.93 54.66 54.33 THERM. EFFIC. 52.23	POWER 174.12 240.79 292.92 308.93 303.63 271.37 255.71 242.70 212.06	TEMP. 23.55 25.83 28.61 31.53 34.41 36.98 39.40 41.70 43.70 STORAGE TEMP.
8.00 9.00 10.00 12.00 13.00 15.00 16.00 MONTH =J TIME 8.00 9.00	TEMP, 26.95 30.46 34.26 37.48 40.24 42.16 44.28 46.33 47.80 UNIE COL. OUT. TEMP, 32.76 36.69	EFFIC. 55.48 55.54 55.36 55.27 55.10 54.93 54.66 54.33 THERM. EFFIC.	POWER 174.12 240.79 292.92 308.93 303.63 271.37 255.71 242.70 212.06 USEFUL POWER 225.04	TEMP. 23.55 25.83 28.61 31.53 34.41 36.98 39.40 41.70 43.70 STORAGE TEMP. 28.43
8.00 9.00 11.00 11.00 13.00 14.00 15.00 16.00 MONTH =J TIME 8.00 9.00	TEMP. 26.95 30.46 34.26 37.48 40.24 42.16 44.28 46.33 47.80 UNE COL. OUT. TEMP. 32.76	EFFIC. 55.48 55.50 55.44 55.36 55.27 55.10 54.93 54.66 54.33 THERM. EFFIC. 52.23 52.21	POWER 174.12 240.79 292.92 308.93 303.63 271.37 255.71 242.70 212.06 USEFUL POWER 225.04 287.31	TEMP. 23.55 25.83 28.61 31.53 34.41 36.98 39.40 41.70 43.70 STORAGE TEMP. 28.43 31.15 34.22 37.44
8.00 9.00 10.00 12.00 13.00 15.00 16.00 MONTH = J TIME 8.00 9.00 10.00	TEMP. 26.95 30.46 34.26 37.48 40.24 42.16 44.28 46.33 47.80 UNB COL. OUT. TEMP. 32.76 36.69 40.40 43.92	EFFIC. 55.48 55.50 55.44 55.36 55.27 55.10 54.93 54.66 54.33 THERM. EFFIC. 52.23 52.21 52.16	POWER 174.12 240.79 292.92 308.93 303.63 271.37 255.71 242.70 212.06 USEFUL POWER 225.04 287.31 323.94	TEMP. 23.583 28.61 31.53 34.41 36.98 39.40 41.70 43.70 STORAGE TEMP. 28.43 31.15 34.22 37.44 40.73
8.00 9.00 11.00 11.00 13.00 14.00 15.00 16.00 MONTH =J TIME 8.00 9.00	TEMP, 26.95 30.46 34.26 37.48 40.24 42.16 44.28 46.33 47.80 UNIE COL. OUT. TEMP, 32.76 36.69 40.40	EFFIC. 55.48 55.50 55.44 55.36 55.27 55.10 54.66 54.33 THERM. EFFIC. 52.23 52.21 52.21 52.08	POMER 174.12 240.79 292.92 308.93 303.63 271.37 255.71 242.70 212.06 USEFUL POMER 225.04 287.31 323.94 340.22 346.47 337.97	TEMP. 23.55 25.83 28.61 31.53 34.41 36.98 39.40 41.70 43.70 STORAGE TEMP. 28.43 31.15 34.22 37.44 40.73 43.93
8.00 9.00 10.00 11.00 12.00 14.00 15.00 16.00 MONTH =J TIME 8.00 9.00 10.00 11.00	TEMP, 26.95 30.46 34.26 37.48 40.24 42.16 44.28 46.33 47.80 UNIE COL. OUT. TEMP. 32.76 36.69 40.40 43.92 47.31	EFFIC. 55.48 55.50 55.44 55.36 55.27 55.10 54.96 54.33 THERM. EFFIC. 52.21 52.16 52.98 51.98	POMER 174.19 292.92 308.93 303.63 271.37 242.70 212.06 USEFUL POMER 225.04 287.31 323.94 340.22 346.47 337.97 321.40	TEMP. 23.5.83 28.61 31.53 34.41 36.98 39.40 41.70 43.70 STORAGE TEMP. 28.43 31.15 34.22 37.44 40.73 43.93 46.97
8.00 9.00 10.00 12.00 13.00 14.00 15.00 MONTH =J TIME 8.00 9.00 10.00 11.00 12.00 13.00 14.00	TEMP. 26.95 30.46 34.26 37.48 40.24 42.16 44.28 46.33 47.80 UNIE COL. OUT. TEMP. 32.76 36.69 40.40 43.92 47.31 50.34 53.08 55.47	EFFIC. 55.48 55.50 55.46 55.27 55.10 54.93 54.65 54.33 THERM. EFFIC. 52.23 52.21 52.26 52.28 51.83 51.48	USEFUL POMER 225.04 340.22 346.47 31 323.94 340.22 346.47 37 37.97 321.40 295.40	TEMP. 23.55 25.83 28.61 31.53 34.41 36.98 39.40 41.70 43.70 STORAGE TEMP. 28.43 31.15 34.22 37.44 40.73 43.93 46.97 49.78
8.00 9.00 10.00 12.00 13.00 15.00 16.00 MONTH =J TIME 8.00 9.00 10.00 11.00 12.00 13.00	TEMP, 26.95 30.46 34.26 37.48 40.24 42.16 44.28 46.33 47.80 UINE COL. OUT. TEMP, 32.76 36.69 40.40 43.92 47.31 50.34 53.08	EFFIC. 55.46 55.46 55.46 55.27 55.193 54.66 54.33 THERM. EFFIC. 52.21 52.16 52.21 52.16 53.88 51.68	POMER 174.19 292.92 308.93 303.63 271.37 242.70 212.06 USEFUL POMER 225.04 287.31 323.94 340.22 346.47 337.97 321.40	TEMP. 23.5.83 28.61 31.53 34.41 36.98 39.40 41.70 43.70 STORAGE TEMP. 28.43 31.15 34.22 37.44 40.73 43.93 46.97

Table 3. Mean daily energy collected

MONTH	ENERGY (Wh)
JAN	1544
FEB	1941
MAR	2587
APR	2577
MAY	2307
JUN	2755
JUL	3051
AUG	3406
SEP	3730
ОСТ	3221
NOV	2026
DEC	2006

Table 4. Collector performance

	_	
ITEM	TEST SLOPE	TEST INTERCEPT
Predicted performance	0.353	0.656
Actual performance	0.441	0.642
% difference	24.9	2.1

Table 5. Comparison of actual and predicted system performance

MONTH	PREDICTED PERFORMANCE (using actual optical efficiency)	ACTUAL PERFORMANCE	ENERGY GAIN % DIFFERENCE
MARCH	2506 Wh	2403 Wh	-4.1
APRIL	2527 Wh	2351 Wh	-6.9
MAY	2254 Wh	2241 Wh	-0.6
JUNE	2696 Wh	2713 Wh	+0.6

CONCLUSIONS

The simulation program can predict the PTC system performance to an accuracy of 7% and therefore the model can be successfully used for long term parabolic trough collector system performance prediction.

NOMENCLATURE

A, Aperture area, m²

A. Geometric factor

A. Receiver area, m²

CR Concentration ratio

D Receiver diameter, m

D. Inside receiver diameter, m

D. Outside receiver diameter, m

f Focal distance, m

F_R Heat removal factor

Gr Grashof number, dimensionless

h Loss coefficient, W/m²K

h, Heat transfer coefficient inside tube, W/m²K

h. Heat transfer coefficient outside tube, W/m²K

h, Parabola height, m

k Thermal conductivity, W/mK

I Beam solar radiation, W/m²

Nu Nuselt number, dimensionless

Pr Prandtl number, dimensionless

q_u Useful power, W

U₁ Heat loss coefficient, W/m²K

T_i Collector inlet temperature, K

T, Ambient temperature, K

W, Collector aperture, m

Greek letters:

 α - Absorptance of receiver coating

 ρ – Mirror reflectivity

τ - Transmittance of receiver cover

γ - Intercept factor

Θ - Angle of incidence, deg.

n - Thermal efficiency

n_o - Optical efficiency

REFERENCES

- [1] Kalogirou S. and Lloyd S., Use of Parabolic Trough Collectors for Hot Water Production in Cyprus A Feasibility Study, Renewable Energy Journal, Vol.2, No.2, pp. 117–124, 1992.
- [2] Murphy L.M. and Keneth E., Steam Generation in Line-Focus Solar Collectors: A Comparative Assessment of Thermal Performance, Operating Stability, and Cost Issues, SERI, 1984.
- [3] Kalogirou S., Solar Energy Utilisation Using Parabolic Trough Collector in Cyprus, Master's thesis, The Polytechnic of Wales, 1991.
- [4] Prapas D., Norton B. and Probert D., Optics of Parabolic Trough Solar Energy Collectors Possessing Small Concentration Ratios, Solar Energy, Vol.39, pp. 541-550, 1987.
- [5] Guven H.M. and Bannerot R.B., Derivation of Universal Error Parameters for Comprehensive Optical Analysis of Parabolic Troughs, Solar Engineering, proceedings of the ASME-ASRE Solar energy conference, Knoxville, pp. 168-174, 1985.
- [6] Mullick S.C. and Nanda S.K., An Improved Technique for Computing the Heat Loss Factor of a Tubular Absorber, Solar Energy, Vol.42, pp. 1-7, 1989.
- [7] Holman J.P., Heat Transfer, McGraw-Hill Book Company, 1989.
- [8] ASHRAE Standard 93, Method of Testing to Determine the Thermal Performance of Solar Collectors, 1986